

NOMINAL CROSS SECTIONAL AREA mm ²	NOMINAL THICKNESS OF INSULATION mm	NOMINAL OVERALL DIAMETER mm		MINIMUM RESISTANCE OF INSULATION AT 90°C Mohms/km	NOMINAL WEIGHT kg/km
		Lower Limit	Upper Limit		
0.5	0.6	2.1	2.6	0.015	8.7
0.75	0.6	2.2	2.8	0.011	11.3
1	0.6	2.4	2.9	0.01	13.9
1.5	0.7	2.8	3.5	0.010	19.3
2.5	0.8	3.4	4.3	0.009	30.9
4	0.8	3.9	4.9	0.007	44.9
6	0.8	4.4	5.5	0.006	64.2
10	1	5.7	7.1	0.0056	108.2
16	1	6.7	8.4	0.0046	163.4
25	1.2	8.4	10.6	0.0044	248.1
35	1.2	9.7	12.1	0.0038	340.6
50	1.4	11.5	14.4	0.0037	484.2
70	1.4	13.2	16.6	0.0032	671
95	1.6	15.1	18.8	0.0032	895.8
120	1.6	16.7	20.9	0.0029	1111.1
150	1.8	18.6	23.3	0.0029	1389.2
185	2	20.6	25.8	0.0029	1724.1
240	2.2	23.5	29.4	0.0028	2225.4